## CALIF ORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7165-0075:208 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653

Contact: Brian Reynolds (203) 484-1200 FAX (203) 484-7309

**DESIGN:** Model MS-9200UD addressable control unit. Local, auxiliary, remote station, central station

and proprietary (protected premise). Refer to listee's data sheet for detailed product description, operational considerations and required/optional accessories. When required,

accessories shall be CSFM listed.

**RATING:** 120 VAC, 60 Hz, 2.06 A Primary, 24 VDC Secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and

in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an addressable fire alarm control panel for use with separately listed compatible

initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm

Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: For <u>Fire Alarm Verification Feature</u> (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 21, 2004 Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager